



* Maximum drainage area contributing to the basin shall be 10 acres.

* Minimum capacity of the basin shall provide storage for the calculated volume of runoff from a 2-year, 24-hour storm per disturbed acre of drainage area. Where no such calculation has been performed, the minimum capacity of the basin shall be 3600 cubic feet per disturbed acre of contributing drainage area.

	NOV 03	1100-00	CITY OF WICHITA FALLS, TX	
	DATE DRAWN	STANDARD DRAWING NO.		
Sediment-Basin.dwg			SEDIMENT BASIN	
ACAD DRAWING NAME	NO.	DATE	DESCRIPTION	BY
	R	E	V	I
	S	I	O	N
	S			
			 CITY ENGINEER	
			NOV 2003	DATE

DISCLAIMER: The use of this standard is governed by the City of Wichita Falls Engineering Department. No warranty of any kind is made by the City of Wichita Falls for any purpose whatsoever. The City of Wichita Falls assumes no responsibility for the conversion of this standard to other formats for incorrect results or damages resulting from its use.